


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CMOH/RCH/54

Dated: 31.05.2023

It is certified that an inspection team headed by Dr. Manoj Kumar Murmu, D.CMOH-1, Dr. Anujit Goswami, D.MPH(Name of Officers with designation) from O/o CHIEF MEDICAL OFFICER OF HEALTH, PURULIA(Name of Department/ Office) inspected the The Assembly of God Church School, Purulia(Name & Address of the school) on 30.05.2023 (date of inspection) and found that the The Assembly of God Church School, Purulia (Name of school) has safe drinking water


facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of Five (5) YearsSignature with Seal: Name DR. KUNAL KANTI DEDesignation CMOH, PURULIAName & Address of the Office / Department : DHFW, PURULIA

To

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


 Principal
 The Assembly of
 God Church School
 Ranchi Road, Purulia

WATER TESTING LABORATORY PURULIA DISTRICT LABORATORY
Under
PURULIA DIVISION
PUBLIC HEALTH ENGINEERING DIRECTORATE
GOVT. OF WEST BENGAL

TEST REPORT

Date of Collection: 23/05/2023			Brought By: Mr.Clayton Francis.		
Place of sample: Assembly of God Church School, Ranchi Road, , Ward No-03, Dist: Purulia (W.B)					
Quantity: 1000ml			Mode of packing: Glass Sterilized Sample Bottle		
Analysis started on: 23/05/2023			Analysis Completed : 24/05/2023		
Type of Sample: Municipality Supply water			Location: Inside Assembly of God Church School		
SL. NO.	PARAMETER	UNIT	RECOMMENDED DRINKING WATER QUALITY as per IS: 10500-2012		Test Result
			Desirable/ Acceptable Limit	Permissible Limit (Max.)	
A. Physical and Chemical results					
1.	PH	Unit	6.5-8.5	No relaxation	7.24
2.	Total Hardness, as CaCO ₃	Mg/l	200	600	44.71
3.	Iron. As Fe, max	Mg/l	0.3	1.00	0.01
4.	Mn	Mg/l	0.1	0.3	0.01
5.	Fluoride. Max	Mg/l	1.00	1.5	0.53
6.	Turbidity	NTU	1	5	0.87
7.	TDS	Mg/l	500	2000	100.3
8.	Residual Chlorine as Rcl ₂	Mg/l	0.2	1.0	0.0
B. Bacteriological results					
1.	Total Coli form Bacteria	CFU/100ml	Absent	Absent	Absent
2.	Faecal coli form	CFU/100ml	Absent	Absent	Absent

Remarks-All the above parameters is under permissible limit,

(Signature)
24/05/2023

SIGNATURE



**PURULIA DISTRICT WATER TESTING
LABORATORY, PHED**
S.M. CHEMIST & MICROBIOLOGIST
District Water Testing Laboratory