



Government Of West Bengal  
Office Of The Divisional Fire Officer,Purulia  
West Bengal Fire & Emergency Services  
Purulia Fire Station, Ranchi Road,Purulia, Pin:- 723101

Memo no.:IND/WB/FES/20182019/32467

Date: 01-12-2022

**From:**  
Divisional Fire Officer,Purulia  
West Bengal Fire & Emergency Services

**To:** The Assembly of God Church School Purulia  
191, Ranchi Road, ward no. 03, under Purulia Municipality, P.O, P.S Dist. Purulia.,PIN 723101

**Sub:** Renewal of Fire Safety Certificate for the existing construction of G+2 storied building (Old Block) under group educational in favour of 'The Assembly of God Church School Purulia' ,at the premises no. 191, Ranchi Road, ward no. 03, under Purulia Municipality, P.O. Purulia, P.S. Purulia (Town), Dist. Purulia. PIN 723101 West Bengal

This is in reference to your application no. 0125191221600086 dated 05-11-2022 regarding the Renewal of Fire Safety Certificate for the existing construction of G+2 storied building (Old Block) under group educational in favour of 'The Assembly of God Church School Purulia' ,at the premises no. 191, Ranchi Road, ward no. 03, under Purulia Municipality, P.O. Purulia, P.S. Purulia (Town), Dist. Purulia. PIN 723101 West Bengal

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

- 1)At least 10,000lts water capacity terrace level water reservoir for only Fire Fighting purpose with replenishing arrangement @1000lts/min. preferably from two different sources of water supply shall be provided for fire fighting purpose. One electric and one diesel pump of mini. Capacity 450LPM shall be provided to supply requisite water pressure not less than 2kg/cm<sup>2</sup> at terrace level as well as Hose Reel system shall be arrange at each floor level, which shall be connected directly from the overhead roof tank through automatically operated booster pump confirming the relevant IS specification, within three months from issue of the certificate.
- 2)Provision of Hose Reel shall be arrange at each floor level, which shall be connected directly from the overhead roof tank through automatically operated terrace level booster pump confirming the relevant IS specification. The length of the

hose reel should be such that at the time of fully extension no part of the protected floor is more than 6m. away from the nozzle.

3) Driveway must be free of any type of obstruction for easy movement of fire appliances.

No parking will be allowed on the drive way.

- 4) To eliminate risk of fire hazard, good housekeeping both for inside and outside of the buildings shall be strictly maintained.
  - 5) Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
  - 6) A fire control room including a closed circuit TV system will have to be maintained which observe all floor of the building.
  - 7) The notice of fire fighting and evacuation plan from the building shall be prepared and displayed at all suitable places of the building.
  - 8) The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
  - 9) Mock Fire practice and evacuation drill shall be performed periodically with all teachers, non-teaching staff and students of the occupancy.
  - 10) Transformer and switchgear room shall be protected with automatic CO<sub>2</sub> or DCP fire extinguisher conforming I.S specification.
  - 11) A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.
  - 12) Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
  - 13) Periodical flushing of water in the hydrant pipe line shall be made to maintain the efficiency working performance of above mentioned system.
  - 14) The fire and electrical safety audit to be conducted at a regular interval and to be recorded in the fire prevention maintenance register.
  - 15) Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
  - 16) Directional sign of escape route shall be displayed prominently.
  - 17) Fire Suppression System and Emergency Lighting always attached to Emergency Backup.
  - 18) This Fire Safety certificate is valid for three years, subject to fulfill above recommendation within stipulated period and has to be renewed every three years from the date of issue of this letter.
- Any deviation and changes the nature of the use of the building in respect of submitted plan drawing, without obtaining prior permission from the office, the FSC shall be treated cancelled.



Signature valid

Digitally Signed:  
Name: PLABAN MOJIB  
Date: 01-Dec-2023 17:49  
Reason: Approved  
Location: West Bengal

Divisional Fire Officer, Purulia  
West Bengal Fire & Emergency Services